

定常流量法(SHASE-S206)による負荷流量と適用

		5HF																16階		20階									
		4HF																16階		20階									
		4SL+4SLT																10階		12階		14階							
		3SL																8階		10階		12階		14階					
		3SL																3.6		3.4		3.2		3.0					
		3SL																2.8											
便器		洗面器	洗濯機	浴槽	台所流し	手洗器	スロップシンク	流量	脂層	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
1 器具	○							管定常流量		0.039	0.052	0.065	0.078	0.091	0.104	0.117	0.130	0.143	0.156	0.169	0.182	0.195	0.208	0.221	0.234	0.247	0.260	0.273	0.286
								立て管流量		3.0	3.0	3.0	3.0	3.1	3.2	3.2	3.3	3.3	3.4	3.4	3.5	3.5	3.6	3.7	3.7	3.8	3.8	3.9	3.9
	○							横主管流量		1.9	1.9	1.9	1.9	1.9	2.0	2.0	2.1	2.2	2.2	2.3	2.3	2.4	2.4	2.5	2.5	2.6	2.6	2.7	2.7
								管定常流量		0.050	0.060	0.075	0.090	0.105	0.120	0.135	0.150	0.165	0.180	0.195	0.210	0.225	0.240	0.255	0.270	0.285	0.300	0.315	0.330
2 器具	○							立て管流量		2.1	2.1	2.1	2.1	2.2	2.2	2.3	2.4	2.5	2.5	2.6	2.6	2.7	2.7	2.8	2.8	2.9	3.0	3.1	3.1
								横主管流量		1.4	1.4	1.4	1.4	1.5	1.6	1.6	1.7	1.7	1.8	1.8	1.9	1.9	2.0	2.0	2.1	2.1	2.2	2.2	
	○							管定常流量		0.090	0.120	0.150	0.180	0.210	0.240	0.270	0.300	0.330	0.360	0.390	0.420	0.450	0.480	0.510	0.540	0.570	0.600	0.630	0.660
								立て管流量		1.6	1.7	1.9	2.0	2.1	2.2	2.3	2.4	2.5	2.5	2.6	2.7	2.8	2.9	2.9	3.0	3.1	3.2	3.2	3.3
3 器具	○	○						管定常流量		0.129	0.172	0.215	0.258	0.301	0.344	0.387	0.430	0.473	0.516	0.559	0.602	0.645	0.688	0.731	0.774	0.817	0.860	0.903	0.946
								立て管流量		3.2	3.4	3.6	3.8	4.0	4.1	4.3	4.4	4.6	4.7	4.8	5.0	5.1	5.2	5.3	5.5	5.6	5.7	5.8	5.9
	○							横主管流量		2.1	2.3	2.5	2.6	2.8	2.9	3.0	3.2	3.3	3.4	3.5	3.7	3.8	3.9	4.0	4.1	4.2	4.3	4.4	4.5
								管定常流量		0.051	0.068	0.085	0.102	0.119	0.136	0.153	0.170	0.187	0.204	0.221	0.238	0.255	0.272	0.289	0.306	0.323	0.340	0.357	0.374
4 器具	○							管定常流量		3.0	3.0	3.0	3.1	3.2	3.3	3.4	3.4	3.5	3.6	3.7	3.7	3.8	3.9	3.9	4.0	4.1	4.1	4.2	4.2
								横主管流量		1.9	1.9	1.9	2.0	2.0	2.1	2.2	2.3	2.3	2.4	2.5	2.6	2.7	2.7	2.8	2.8	2.9	3.0	3.0	
	○							管定常流量		0.141	0.188	0.235	0.282	0.329	0.376	0.423	0.470	0.517	0.564	0.611	0.658	0.705	0.752	0.799	0.846	0.893	0.940	0.987	1.034
								立て管流量		3.3	3.5	3.7	3.9	4.1	4.2	4.4	4.5	4.7	4.9	5.0	5.1	5.3	5.4	5.5	5.6	5.8	5.9	6.0	6.1
5 器具 以上	○							横主管流量		2.2	2.3	2.5	2.6	2.7	2.9	3.0	3.1	3.2	3.3	3.4	3.5	3.6	3.7	3.8	3.9	4.0	4.1	4.5	4.6
								管定常流量		0.116	0.148	0.185	0.222	0.259	0.296	0.333	0.370	0.407	0.444	0.481	0.515	0.555	0.592	0.629	0.666	0.703	0.740	0.777	0.814
	○							立て管流量		3.0	3.2	3.5	3.7	3.9	4.1	4.2	4.3	4.5	4.6	4.7	4.8	4.9	5.0	5.2	5.3	5.3	5.5	5.6	
								横主管流量		2.0	2.2	2.3	2.5	2.6	2.7	2.9	3.0	3.1	3.2	3.3	3.4	3.5	3.6	3.7	3.8	3.9	4.0	4.1	
5 器具 以上	○							管定常流量		0.140	0.194	0.243	0.291	0.340	0.388	0.437	0.485	0.534	0.582	0.631	0.679	0.728	0.776	0.825	0.873	0.922	0.970	1.019	1.067
								立て管流量		3.3	3.5	3.8	3.9	4.1	4.2	4.4	4.6	4.8	4.9	5.0	5.1	5.3	5.4	5.5	5.6	5.7	5.8	5.9	
	○							横主管流量		2.1	2.3	2.5	2.6	2.7	2.9	3.1	3.2	3.3	3.5	3.6	3.7	3.8	3.9	4.0	4.1	4.2	4.3	4.4	
								管定常流量		0.127	0.162	0.203	0.243	0.284	0.324	0.365	0.405	0.446	0.486	0.527	0.567	0.608	0.648	0.689	0.729	0.770	0.810	0.851	0.891
5 器具 以上	○							立て管流量		2.3	2.5	2.6	2.7	2.9	3.1	3.2	3.4	3.5	3.6	3.7	3.8	3.9	4.0	4.1	4.2	4.3	4.4	4.6	
								横主管流量		1.9	2.1	2.3	2.5	2.6	2.8	3.0	3.2	3.3	3.5	3.6	3.8	3.9	4.0	4.1	4.2	4.3	4.5	4.6	
	○							管定常流量		0.139	0.178	0.223	0.267	0.312	0.356	0.401	0.445	0.490	0.534	0.579	0.623	0.668	0.712	0.757	0.801	0.846	0.890	0.935	0.979
								立て管流量		2.3	2.5	2.6	2.8	3.1	3.2	3.4	3.5	3.6	3.7	3.8	4.0	4.1	4.2	4.3	4.4	4.5	4.7		
5 器具 以上	○							横主管流量		1.6	1.7	1.9	2.0	2.2	2.3	2.4	2.5	2.7	2.8	2.9	3.0	3.1	3.2	3.3	3.4	3.5	3.6	3.7	
								管定常流量		0.131	0.168	0.210	0.252	0.294	0.336	0.378	0.420	0.462	0.504	0.546	0.588	0.630	0.672	0.714	0.756	0.798	0.840	0.882	0.924
	○							立て管流量		2.3	2.5	2.6	2.8	3.0	3.1	3.3	3.4	3.5	3.7	3.8	3.9	4.0	4.1	4.2	4.3	4.4	4.5	4.7	
								横主管流量		1.6	1.7	1.8	2.0	2.1	2.2	2.4	2.5	2.6	2.7	2.8	2.9	3.0	3.1	3.2	3.3	3.4	3.5	3.6	
5 器具 以上	○							管定常流量		0.256	0.334	0.418	0.501	0.585	0.668	0.752	0.835	0.919	1.002	1.086	1.169	1.253	1.336	1.420	1.503	1.587	1.670	1.754	1.837
								立て管流量		3.8	4.1	4.4	4.7	4.9	5.2	5.4	5.6	5.8	6.1	6.2	6.4	6.6	6.8	7.0	7.2	7.4	7.5	7.7	
	○							横主管流量		2.6	2.9	3.1	3.4	3.6	3.8	4.0	4.2	4.4	4.6	4.8	5.0	5.2	5.4	5.5	5.7	5.9	6.0	6.2	
								管定常流量		0.178	0.230	0.288	0.345	0.403	0.460	0.518	0.575	0.633	0.690	0.748	0.805	0.863	0.920	0.978	1.035	1.093	1.150	1.208	1.265
5 器具 以上	○							立て管流量		3.4	3.6	3.9	4.1	4.3	4.5	4.7	4.9	5.1	5.2	5.4	5.5	5.7	5.9	6.0	6.2	6.4	6.5		
								横主管流量		2.3	2.5	2.7	2.9	3.1	3.2	3.4	3.6	3.7	3.9	4.0	4.2	4.3	4.4	4.6	4.7	4.8	5.0		
	○							管定常流量		0.170	0.220	0.275	0.330	0.385	0.440	0.495	0.550	0.605	0.660	0.715	0.770	0.825	0.880	0.935	0.990	1.045	1.100	1.155	1.210
								立て管流量		3.4	3.6	3.9	4.1	4.3	4.4	4.6	4.8	5.0	5.1	5.3	5.4	5.6	5.7	5.9	6.0	6.1	6.3		
5 器具 以上	○							横主管流量		2.3	2.5	2.7	2.8	3.0	3.2	3.4	3.5	3.7	3.8	4.0	4.2	4.3	4.5	4.6	4.7	4.8	5.0		
								管定常流量		0.229	0.273	0.347	0.447	0.522	0.596	0.671	0.745	0.820	0.894	0.963	1.043	1.118	1.192	1.267	1.341	1.416	1.490	1.565	1.639
	○							立て管流量		2.6	3.0	3.3	3.5	3.7	3.9	4.1	4.3	4.5	4.6	4.8	5.0	5.1	5.3	5.5	5.6	5.8	5.9	6.1	
								横主管流量		1.9	2.1	2.4	2.5	2.7	2.9	3.1	3.3	3.4	3.6	3.7	3.9	4.0	4						



79

□ 4SL II シリーズ
適用範囲

□ 4SFの適用範囲

集合管システムの早見表

25階 18.8	30階 18.2	35階 17.6	40階 17.0	45階 16.4	50階 15.7	55階 15.1	60階 14.5
25階 9.4	30階 9.2	35階 8.8	40階 8.5	45階 8.2	50階 7.8	55階 7.5	60階 7.2
25階 5.6	30階 5.4						